

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corroston Control

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1	8.29				3	IIIIIIIIIIIII
2	8,57					been met for this day? PWS ID: 41
3	7,53					uno day.
4	4.33					System Name: Colorado Lake Cooperativa
5	8.27					Entry Point: Unit 1100
6	8.23					Sample Period: Dec 2021
7	8,33					Month/Year
8	8.45					Number of excursions* during this month:
9	9,00					(Count the number of days when any WQP was
10	8.26					less than the minimum required)
11	7,99					
12	8,33					Total excursions during the previous 5 months:
13	8,36					(Over 9 excursions in 6 months is a violation. Entry
14	8.07					Point and Distribution excursions are cumulative)
15	8.20					For OHA use only
16	8.26					
17	8.17					Minimum Water Quality
18	8,06					Parameters as set by
19	8.10					nu Co
20	8.15					pH = (Allcolinitus)
21	8,21					Alk (Alkalinity)
22	8.11					PO4 (Orthophosphate)
23	8.06					Other(
24	7,52					
25	7,55					
26	7,93					
27	7,77					Print Name: Jin Foster
28	8,14					Signature: in Fate
29	8,39					Date: 1/10/202/2
30	7.85					
31	7.81					Send to DWP within 10 days after end of sampling period
1 = 0		ursion) Tota	I N's		Sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/