

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1	7,83				
2	7.72				
3	7,91				
4	8,13				
5	7.87				
6	8,22				
7	8,36				
8	8,11				
9	8,15				
10	8.22				
11	8.31				
12	8.21				
13	8,43				
14	8.38				
15	8.31				
16	8.29				
17	8,43				
18	8,44				
19	8,38				
20	7.80				
21	753				
22	8.26				
23	8.51				
24	8.48				
25	7.53				
26	8.32				
27	8.46				
28	8.25				
29	8.43				
30	8.46				
31					
No = N	V = Exc	ursion) Tota	I N's	

< <have minimums<="" th=""><th colspan="3">ENTRY POINT</th></have>	ENTRY POINT				
been met for this day?	PWS ID: 41 00 232				
System Name: Colorado Lake Coop					
Entry Poi	nt: Unit 1100				
Sample P	Period: Jan 2022				
	Month/Year				

Number of excursions* during this month: \(\) (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:_ (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

	num W	ater Quality as set by
pH [Ę	(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Jim Foster
Signature: in Fatr
Date: 2/4/22
Send to DWP within 10 days after end of

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/