

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	8.21				
2	8.11				
3	7.51				
4	8.22				
5	8.22				
6	8.29				
7	8.13				
8	7.83				
9	8.15				
10	8.28				
11	7.77				
12	8.21				
13	8.08				
14	8.17				
15	8.05				
16	8.11				
17	8.22				
18	8.33				
19	8.26				
20	8.03				
21	8.24				
22	8.10				
23	8.03				
24	8.28				
25	7.64				
26	8.06				
27	8.13				
28	8.27				
29	8.09				
30	8.15				
31	7.85				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Colorado Lake Coop

Entry Point: Unit 1100

Sample Period: May 2022  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH    
 Alk  (Alkalinity)   
 PO4  (Orthophosphate)   
 Other  (\_\_\_\_\_)

Print Name: Jim Foster

Signature: Jim Foster

Date: 6/10/22

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's