

Lead & Copper Rule Corrosion Control

| Day | рН | Alk | Phos | Other | Y/N | < <have< th=""></have<> |
|--|---------|--------|--------|-------|-----|---|
| 1 | 8,61 | | | | | minimums ENTRY POINT |
| 2 | 7,92 | | | | | been met for this day? PWS ID: 41 |
| 3 | 7.82 | | | | | uno day. |
| 4 | 7,90 | | | | | . System Name: Colorado Lake Coop |
| 5 | 7.63 | | | | | Entry Point: Unit 1100 |
| 6 | 7.75 | | | | | Sample Period: Sep 2022 |
| 7 | 7,56 | | | | | ` Month/Year |
| 8 | 7.51 | | | | | Number of excursions* during this month: |
| 9 | 8.45 | | | | | (Count the number of days when any WQP was |
| 10 | 8,43 | | | | | less than the minimum required) |
| 11 | 8,40 | | | | | |
| 12 | 8.36 | | | | | Total excursions during the previous 5 months: |
| 13 | 8,30 | | | | | (Over 9 excursions in 6 months is a violation. Entry |
| 14 | 8,15 | | | | | Point and Distribution excursions are cumulative) |
| 15 | 8,01 | | | | | For OHA use only |
| 16 | 7.76 | | | | | Tot of hit doe of hy |
| 17 | 7.70 | | | | | Minimum Water Quality |
| 18 | 7.68 | r | | | | Parameters as set by |
| 19 | 8.48 | - 50 | -3 | | | nu 🗔 |
| 20 | 7.65 | | | | | pH (Allcolinitus) |
| 21 | 8.47 | | | | | Alk (Alkalinity) |
| 22 | 7.68 | | | | | PO4 (Orthophosphate) |
| 23 | 7,68 | | | | | Other |
| 24 | 7.67 | | | | | |
| 25 | 7,66 | | | | | |
| 26 | 7,68 | | | | | |
| 27 | 7,70 | | | | | Print Name: Dim Foster |
| 28 | 7.71 | | | | | Signature: |
| 29 | 7.75 | | | | | Date: 10/10/2622 |
| 30 | 7.61 | | | | | |
| 31 | | | | | | Send to DWP within 10 days after end of sampling period |
| No = N | V = Exc | ursion |) Tota | I N's | | Sampling period |
| OHA Drinking Water Program PO Box 14350 Portland OR 97293-0350 | | | | | | |

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/