

Day	pH	Alk	Phos	Other	Y/N
1	7.0				
2	8.07				
3	8.06				
4	8.23				
5	8.25				
6	8.33				
7	8.37				
8	8.33				
9	8.35				
10	8.40				
11	8.33				
12	8.30				
13	8.33				
14	8.32				
15	8.25				
16	8.19				
17	8.40				
18	8.09				
19	8.32				
20	8.42				
21	8.44				
22	8.02				
23	7.52				
24	7.60				
25	8.30				
26	8.32				
27	8.06				
28	8.18				
29	8.35				
30	8.18				
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: Colorado Lake Coop

Entry Point: Unit 1100

Sample Period: Apr / 2023  
Month/Year

Number of excursions\* during this month: 1  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH    
 Alk  (Alkalinity)   
 PO4  (Orthophosphate)   
 Other  (\_\_\_\_\_)

Print Name: James Foster

Signature: [Signature]

Date: 5/10/23

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's