

Day	pH	Alk	Phos	Other	Y/N
1	8.20				
2	8.14				
3	7.55				
4	7.81				
5	8.03				
6	8.06				
7	8.97				
8	7.77				
9	7.76				
10	7.74				
11	7.78				
12	7.82				
13	7.59				
14	9.87				
15	9.10				
16	7.58				
17	8.30				
18	8.06				
19	7.69				
20	7.70				
21	7.60				
22	9.12				
23	9.12				
24	9.37				
25	7.80				
26	7.73				
27	7.71				
28	7.69				
29	7.71				
30	7.81				
31	7.75				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Colorado Lake Coop

Entry Point: Unit 1100

Sample Period: Dec 2023
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Jim Foster

Signature: [Signature]

Date: 1/1/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's