



## Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.66				Y
2	7.62				Y
3	7.74				Y
4	7.72				Y
5	7.82				Y
6	7.76				Y
7	7.72				Y
8	7.80				Y
9	7.84				Y
10	7.78				Y
11	7.92				Y
12	7.96				Y
13	7.76				Y
14	7.81				Y
15	7.67				Y
16	7.76				Y
17	7.60				Y
18	7.56				Y
19	7.55				Y
20	7.83				Y
21	8.36				Y
22	8.25				Y
23	8.20				Y
24	8.28				Y
25	8.67				Y
26	8.35				Y
27	7.97				Y
28	8.42				Y
29	8.40				Y
30	8.36				Y
31	8.21				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

**Entry Point**  
PWS ID: 41 00232

**System Name:** Colorado Lake Coop  
**Entry Point:** Unit 1105  
**Sample Period:** January 2024  
Month / Year

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Sam Murk  
 Signature:   
 Date: 2/3/2024  
 Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>