



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.72				Y
2	8.21				Y
3	8.22				Y
4	8.25				Y
5	9.00				Y
6	8.20				Y
7	8.28				Y
8	8.34				Y
9	8.34				Y
10	7.50				Y
11	9.20				Y
12	9.32				Y
13	8.29				Y
14	8.23				Y
15	8.25				Y
16	8.06				Y
17	8.31				Y
18	8.20				Y
19	8.21				Y
20	8.09				Y
21	8.22				Y
22	8.18				Y
23	7.96				Y
24	8.00				Y
25	8.26				Y
26	8.07				Y
27	8.03				Y
28	8.04				Y
29	8.11				Y
30	na				Y
31	na				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

Entry Point
PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: January 2024 Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Sam Murk
 Signature:
 Date: 3/1/2024
 Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>