



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.12				Y
2	8.03				Y
3	7.89				Y
4	7.88				Y
5	7.90				Y
6	7.98				Y
7	7.89				Y
8	8.09				Y
9	7.94				Y
10	7.99				Y
11	7.93				Y
12	8.05				Y
13	7.74				Y
14	7.88				Y
15	8.10				Y
16	8.20				Y
17	7.83				Y
18	7.88				Y
19	7.76				Y
20	7.60				Y
21	7.83				Y
22	7.86				Y
23	7.93				Y
24	7.91				Y
25	7.86				Y
26	7.70				Y
27	7.68				Y
28	7.75				Y
29	8.86				Y
30	7.99				Y
31	7.59				Y
(No = N = Excursion) Total N's					0

<< Have minimums **Entry Point** been met for PWS ID: 41 00232 this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: February 2024

Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Sam Murk
 Signature:
 Date: 3/31/2024
 Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>