



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.64				Y
2	7.68				Y
3	7.66				Y
4	7.61				Y
5	8.48				Y
6	7.64				Y
7	7.86				Y
8	7.70				Y
9	7.72				Y
10	8.62				Y
11	8.75				Y
12	8.45				Y
13	8.62				Y
14	8.56				Y
15	8.48				Y
16	8.80				Y
17	7.61				Y
18	7.70				Y
19	7.65				Y
20	8.57				Y
21	8.40				Y
22	8.34				Y
23	8.55				Y
24	7.95				Y
25	8.04				Y
26	7.75				Y
27	8.46				Y
28	8.59				Y
29	8.55				Y
30	8.45				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

Entry Point
PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: April 2024
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	=	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		(_____)

Print Name: Sam Murk
 Signature: *Sam Murk*
 Date: 5/1/2024
 Send to DWP within 10 days after end of sampling period