



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.29				Y
2	8.26				Y
3	8.32				Y
4	8.21				Y
5	8.25				Y
6	7.76				Y
7	7.56				Y
8	7.52				Y
9	7.63				Y
10	7.65				Y
11	7.57				Y
12	7.99				Y
13	8.30				Y
14	7.70				Y
15	7.66				Y
16	7.62				Y
17	7.68				Y
18	7.62				Y
19	7.72				Y
20	7.61				Y
21	7.61				Y
22	nc				nc
23	nc				nc
24	nc				nc
25	nc				nc
26	7.45				N
27	7.68				Y
28	7.51				Y
29	7.60				Y
30	7.65				Y
31	na				Y
(No = N = Excursion) Total N's					1

<< Have

minimums

been met for

this day?

Entry Point

PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: November 2024

Month / Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.45	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature:

Date: 12/4/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>