



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.73				Y
2	7.36				N
3	7.36				N
4	7.52				Y
5	7.55				Y
6	7.61				Y
7	7.46				N
8	7.48				N
9	7.39				N
10	7.54				Y
11	7.51				Y
12	8.40				Y
13	8.28				Y
14	8.46				Y
15	8.21				Y
16	7.50				Y
17	7.50				Y
18	8.36				Y
19	8.56				Y
20	8.21				Y
21	7.74				Y
22	8.06				Y
23	8.63				Y
24	8.17				Y
25	8.00				Y
26	7.65				Y
27	7.59				Y
28	8.55				Y
29	8.55				Y
30	8.40				Y
31	8.40				Y
(No = N = Excursion) Total N's					7

<< Have

minimums

Entry Point

been met for

PWS ID: 41 00232

this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: December 2024

Month / Year

Number of excursions* during this month: 7

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature: Sam Murk

Date: 12/31/2024

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>