



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.95				Y
2	7.71				Y
3	7.74				Y
4	7.63				Y
5	7.81				Y
6	7.83				Y
7	7.71				Y
8	7.75				Y
9	7.66				Y
10	7.65				Y
11	7.67				Y
12	7.57				Y
13	7.54				Y
14	7.50				Y
15	7.72				Y
16	7.58				Y
17	7.68				Y
18	7.62				Y
19	7.54				Y
20	7.88				Y
21	7.55				Y
22	7.77				Y
23	7.65				Y
24	7.56				Y
25	7.69				Y
26	7.69				Y
27	7.74				Y
28	7.73				Y
29	na				Y
30	na				Y
31	na				Y
(No = N = Excursion) Total N's					0

<< Have

minimums **Entry Point**
 been met for PWS ID: 41 00232
 this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: February 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.5	
Alk	100	(Alkalinity)
PO4	0.1	(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature:

Date: 3/1/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>