



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.58				Y
2	8.23				Y
3	8.34				Y
4	8.58				Y
5	8.58				Y
6	7.64				Y
7	7.65				Y
8	7.67				Y
9	7.50				Y
10	7.73				Y
11	7.62				Y
12	8.28				Y
13	7.73				Y
14	7.60				Y
15	7.67				Y
16	7.51				Y
17	7.98				Y
18	8.09				Y
19	8.21				Y
20	7.84				Y
21	7.68				Y
22	7.94				Y
23	8.00				Y
24	7.75				Y
25	7.54				Y
26	8.96				Y
27	9.03				Y
28	8.93				Y
29	8.92				Y
30	8.84				Y
31	8.86				Y
(No = N = Excursion) Total N's					0

<< Have

minimums **Entry Point**
 been met for PWS ID: 41 00232
 this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: March 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature:

Date: 4/1/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>