



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.20				Y
2	7.63				Y
3	7.70				Y
4	7.73				Y
5	7.71				Y
6	7.72				Y
7	7.67				Y
8	7.62				Y
9	7.69				Y
10	7.73				Y
11	7.61				Y
12	7.72				Y
13	7.79				Y
14	7.61				Y
15	7.69				Y
16	7.71				Y
17	7.54				Y
18	8.09				Y
19	7.70				Y
20	8.65				Y
21	8.10				Y
22	8.00				Y
23	7.83				Y
24	8.02				Y
25	7.82				Y
26	7.88				Y
27	7.88				Y
28	7.88				Y
29	7.67				Y
30	7.86				Y
31	na				Y
(No = N = Excursion) Total N's					0

<< Have

minimums

Entry Point

been met for

PWS ID: 41 00232

this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: June 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	8.20	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature: 

Date: 7/4/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>