



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.94				Y
2	7.59				Y
3	7.77				Y
4	7.91				Y
5	8.46				Y
6	7.88				Y
7	7.72				Y
8	7.54				Y
9	8.13				Y
10	7.58				Y
11	7.87				Y
12	7.80				Y
13	7.82				Y
14	8.23				Y
15	7.91				Y
16	7.57				Y
17	7.70				Y
18	7.31				N
19	7.68				Y
20	7.64				Y
21	7.76				Y
22	7.88				Y
23	8.46				Y
24	7.89				Y
25	7.86				Y
26	7.81				Y
27	7.86				Y
28	8.10				Y
29	8.07				Y
30	7.82				Y
31	7.78				Y
(No = N = Excursion) Total N's					1

<< Have

minimums **Entry Point**
 been met for PWS ID: 41 00232
 this day?

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: July 2025

Month / Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.31	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature: Sam Murk

Date: 7/31/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>