



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.68				Y
2	7.53				Y
3	7.53				Y
4	7.70				Y
5	7.68				Y
6	7.52				Y
7	7.69				Y
8	8.13				Y
9	7.67				Y
10	7.58				Y
11	7.56				Y
12	7.67				Y
13	7.58				Y
14	7.64				Y
15	7.93				Y
16	8.23				Y
17	8.01				Y
18	7.96				Y
19	8.16				Y
20	8.27				Y
21	8.20				Y
22	8.82				Y
23	8.49				Y
24	8.39				Y
25	7.74				Y
26	7.53				Y
27	7.72				Y
28	7.37				N
29	7.77				Y
30	8.18				Y
31	7.91				Y
(No = N = Excursion) Total N's					1

<< Have

minimums

been met for

this day?

Entry Point

PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: August 2025

Month / Year

Number of excursions* during this month: 1

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH		
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Sam Murk

Signature:

Date: 8/31/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>