



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.55				Y
2	8.04				Y
3	7.67				Y
4	7.64				Y
5	7.61				Y
6	7.71				Y
7	7.68				Y
8	7.63				Y
9	8.00				Y
10	8.18				Y
11	8.35				Y
12	8.04				Y
13	8.06				Y
14	8.35				Y
15	7.83				Y
16	7.69				Y
17	7.73				Y
18	7.76				Y
19	7.69				Y
20	7.72				Y
21	7.71				Y
22	7.54				Y
23	7.52				Y
24	7.61				Y
25	7.80				Y
26	7.67				Y
27	7.62				Y
28	7.68				Y
29	7.71				Y
30	7.75				Y
31	na				
(No = N = Excursion) Total N's					0

<< Have

minimums

been met for

this day?

Entry Point

PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: August 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk

PO4

Other

(Alkalinity)

(Orthophosphate)

()

Print Name: Sam Murk

Signature:

Date:

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>