



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.71				Y
2	8.09				Y
3	8.16				Y
4	8.05				Y
5	8.16				Y
6	8.38				Y
7	7.70				Y
8	7.73				Y
9	7.79				Y
10	7.78				Y
11	7.70				Y
12	7.86				Y
13	7.61				Y
14	7.53				Y
15	7.79				Y
16	8.15				Y
17	8.35				Y
18	8.31				Y
19	8.38				Y
20	7.97				Y
21	7.66				Y
22	7.60				Y
23	7.64				Y
24	7.85				Y
25	7.58				Y
26	8.23				Y
27	8.40				Y
28	7.72				Y
29	7.61				Y
30	7.63				Y
31	7.60				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

Entry Point
PWS ID: 41 00232

System Name: Colorado Lake Coop
Entry Point: Unit 1105
Sample Period: October 2025
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only


Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Sam Murk
 Signature: 
 Date: 10/31/2028
 Send to DWP within 10 days after end of sampling period