

Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|---------------------------------------|------|-----|------|-------|----------|
| 1 | 7.60 | | | | Y |
| 2 | 7.69 | | | | Y |
| 3 | 7.63 | | | | Y |
| 4 | 7.76 | | | | Y |
| 5 | 7.73 | | | | Y |
| 6 | 7.85 | | | | Y |
| 7 | 7.90 | | | | Y |
| 8 | 7.56 | | | | Y |
| 9 | 7.64 | | | | Y |
| 10 | 8.29 | | | | Y |
| 11 | 8.34 | | | | Y |
| 12 | 7.79 | | | | Y |
| 13 | 7.61 | | | | Y |
| 14 | 7.65 | | | | Y |
| 15 | 7.72 | | | | Y |
| 16 | 7.71 | | | | Y |
| 17 | 7.70 | | | | Y |
| 18 | 7.62 | | | | Y |
| 19 | 7.61 | | | | Y |
| 20 | 7.75 | | | | Y |
| 21 | 8.18 | | | | Y |
| 22 | 7.66 | | | | Y |
| 23 | 7.73 | | | | Y |
| 24 | 7.64 | | | | Y |
| 25 | 8.01 | | | | Y |
| 26 | 7.82 | | | | Y |
| 27 | 7.72 | | | | Y |
| 28 | 7.81 | | | | Y |
| 29 | 7.69 | | | | Y |
| 30 | 8.21 | | | | Y |
| 31 | 7.63 | | | | Y |
| (No = N = Excursion) Total N's | | | | | 0 |

<< Have minimums been met for this day?

Entry Point
PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: August 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Sam Murk

Signature:

Date: 12/31/2025

Send to DWP within 10 days after end of sampling period