



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.96				Y
2	8.03				Y
3	7.55				Y
4	8.21				Y
5	8.24				Y
6	8.39				Y
7	7.74				Y
8	7.68				Y
9	7.67				Y
10	7.73				Y
11	7.76				Y
12	7.68				Y
13	7.68				Y
14	8.24				Y
15	7.92				Y
16	8.52				Y
17	8.03				Y
18	7.90				Y
19	7.91				Y
20	7.95				Y
21	7.91				Y
22	7.86				Y
23	7.82				Y
24	7.92				Y
25	7.88				Y
26	7.90				Y
27	7.88				Y
28	7.89				Y
29	7.93				Y
30	7.83				Y
31	7.85				Y
(No = N = Excursion) Total N's					0

<< Have minimums been met for this day?

Entry Point

PWS ID: 41 00232

System Name: Colorado Lake Coop

Entry Point: Unit 1105

Sample Period: January 2026

Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text"/>	
Alk	<input checked="" type="checkbox"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Sam Murk
 Signature:
 Date: 1/31/2026
 Send to DWP within 10 days after end of sampling period