



Water Quality Parameter Monitoring From Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.55				Y
2	8.19				Y
3	8.63				Y
4	8.25				Y
5	8.02				Y
6	8.03				Y
7	8.07				Y
8	8.04				Y
9	7.94				Y
10	8.06				Y
11	8.15				Y
12	8.20				Y
13	8.01				Y
14	8.15				Y
15	8.03				Y
16	7.99				Y
17	8.08				Y
18	8.14				Y
19	8.14				Y
20	8.13				Y
21	6.60				N
22	9.12				Y
23	7.50				Y
24	7.96				Y
25	9.13				Y
26	7.95				Y
27	7.77				Y
28	7.84				Y
29	7.98				Y
30	7.72				Y
31	7.89				Y
(No = N = Excursion) Total N's					1

<< Have minimums been met for this day?

Entry Point
PWS ID: 41 00232

System Name: Colorado Lake Coop
Entry Point: Unit 1105
Sample Period: March 2026
Month / Year


Number of excursions* during this month: 1
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Sam Murk
Signature: 
Date: 3/31/2026
Send to DWP within 10 days after end of sampling period