



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.8				Y
3	7.8				Y
4	7.8				Y
5	7.8				Y
6	7.7				Y
7	7.8				Y
8	7.8				Y
9	7.8				Y
10	7.8				Y
11	7.8				Y
12	7.8				Y
13	7.8				Y
14	7.8				Y
15	7.7				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.8				Y
22	7.9				Y
23	7.8				Y
24	7.9				Y
25	7.9				Y
26	7.9				Y
27	7.9				Y
28	7.8				Y
29	7.8				Y
30	7.8				Y
31	7.8				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

**PWS ID: 41** 0 0 2 3 6

**System Name:** Cottage Grove, City of

**Entry Point:** EP-B

**Sample Period:** October / 2023  
Month / Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

**Print Name:** Ryan Kimball

**Signature:**

**Date:** November 01, 2023

Send to DWS within 10 days after end of sampling period