

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.7				Y
4	7.7				Y
5	7.6				Y
6	7.7				Y
7	7.9				Y
8	8.0				Y
9	7.9				Y
10	7.9				Y
11	7.9				Y
12	7.9				Y
13	8.0				Y
14	8.0				Y
15	8.0				Y
16	8.0				Y
17	8.0				Y
18	8.0				Y
19	8.0				Y
20	8.0				Y
21	8.0				Y
22	8.0				Y
23	7.9				Y
24	8.0				Y
25	8.0				Y
26	8.0				Y
27	7.9				Y
28	7.9				Y
29	7.9				Y
30	7.9				Y
31	7.9				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: March / 2024

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Ryan Kimball

Signature:

Date: April 01, 2024

Send to DWS within 10 days after end of sampling period