

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	7.9				Y
5	7.9				Y
6	7.9				Y
7	7.9				Y
8	7.8				Y
9	7.8				Y
10	7.8				Y
11	7.9				Y
12	7.9				Y
13	7.9				Y
14	7.8				Y
15	7.8				Y
16	7.8				Y
17	7.8				Y
18	7.8				Y
19	7.7				Y
20	7.8				Y
21	7.9				Y
22	7.9				Y
23	7.9				Y
24	7.9				Y
25	7.9				Y
26	7.8				Y
27	7.9				Y
28	7.9				Y
29	7.9				Y
30	8.0				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: April / 2024
Month / Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Ryan Kimball

Signature: 

Date: May 01, 2024

Send to DWS within 10 days after end of sampling period