

Day	pH	Alk	Phos	Other	Y/N
1	8.1				Y
2	8.1				Y
3	8.2				Y
4	8.2				Y
5	8.2				Y
6	8.3				Y
7	8.2				Y
8	8.2				Y
9	8.2				Y
10	8.2				Y
11	8.1				Y
12	8.2				Y
13	8.2				Y
14	8.2				Y
15	8.2				Y
16	8.1				Y
17	8.2				Y
18	8.2				Y
19	8.1				Y
20	8.1				Y
21	8.1				Y
22	8.1				Y
23	8.1				Y
24	8.1				Y
25	8.1				Y
26	8.0				Y
27	8.1				Y
28	8.1				Y
29	8.1				Y
30	8.3				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

**PWS ID: 41** 0 0 2 3 6

**System Name:** Cottage Grove, City of

**Entry Point:** EP-B

**Sample Period:** June / 2024  
Month / Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**


pH 7.0

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

**Print Name:** Ryan Kimball

**Signature:** 

**Date:** July 2nd, 2024

Send to DWS within 10 days after end of sampling period