

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	7.9				Y
3	7.9				Y
4	7.9				Y
5	7.9				Y
6	7.9				Y
7	7.8				Y
8	7.8				Y
9	7.9				Y
10	7.8				Y
11	7.8				Y
12	7.8				Y
13	7.9				Y
14	7.9				Y
15	8.0				Y
16	8.0				Y
17	8.1				Y
18	8.1				Y
19	8.0				Y
20	8.0				Y
21	8.0				Y
22	8.0				Y
23	8.0				Y
24	8.0				Y
25	8.0				Y
26	8.0				Y
27	8.0				Y
28	8.0				Y
29	8.1				Y
30	8.0				Y

(No = N = Excursion) Total N's

0

<<Have

minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: April / 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Ryan Kimball

Signature: 

Date: May 01, 2025

Send to DWS within 10 days after end of sampling period