



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				Y
2	8.1				Y
3	8.0				Y
4	8.0				Y
5	7.9				Y
6	7.9				Y
7	7.9				Y
8	7.9				Y
9	8.0				Y
10	8.1				Y
11	8.1				Y
12	8.1				Y
13	8.1				Y
14	8.0				Y
15	8.0				Y
16	8.0				Y
17	8.0				Y
18	8.0				Y
19	8.0				Y
20	8.0				Y
21	8.0				Y
22	8.0				Y
23	8.0				Y
24	8.0				Y
25	8.0				Y
26	8.0				Y
27	7.9				Y
28	7.9				Y
29	7.9				Y
30	7.9				Y
31	8.0				Y

(No = N = Excursion) Total N's

0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41

0	0	2	3	6
---	---	---	---	---

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: October / 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH	7.0
Alk	(Alkalinity)
PO4	(Orthophosphate)
Other	()

Print Name: Ryan Kimball

Signature:

Date: November 03 2025

Send to DWS within 10 days after end of sampling
period