



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	8.1				Y
4	8.1				Y
5	8.1				Y
6	8.1				Y
7	8.1				Y
8	8.1				Y
9	8.1				Y
10	8.0				Y
11	8.1				Y
12	8.1				Y
13	8.1				Y
14	8.1				Y
15	8.1				Y
16	8.1				Y
17	8.2				Y
18	8.2				Y
19	8.2				Y
20	8.2				Y
21	8.1				Y
22	8.1				Y
23	8.1				Y
24	8.1				Y
25	8.1				Y
26	8.0				Y
27	8.0				Y
28	8.1				Y
29	8.1				Y
30	8.1				Y
31	8.1				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: MARCH 2021
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Ryan Kimball

Signature:

Date: April 5 2021

Send to DWS within 10 days after end of sampling period