

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	7.9				Y
5	7.8				Y
6	7.8				Y
7	7.9				Y
8	8.0				Y
9	8.0				Y
10	8.1				Y
11	8.1				Y
12	8.0				Y
13	8.1				Y
14	8.1				Y
15	8.1				Y
16	8.2				Y
17	8.2				Y
18	8.2				Y
19	7.9				Y
20	7.9				Y
21	7.9				Y
22	8.1				Y
23	8.2				Y
24	8.2				Y
25	8.2				Y
26	8.3				Y
27	8.3				Y
28	8.3				Y
29	8.3				Y
30	8.1				Y
31	8.1				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: January / 2022
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Ryan Kimball

Signature:

Date: February 03, 2022

Send to DWS within 10 days after end of sampling period