

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	8.0				Y
5	7.9				Y
6	7.9				Y
7	7.8				Y
8	7.8				Y
9	7.7				Y
10	7.8				Y
11	7.9				Y
12	7.9				Y
13	7.9				Y
14	7.9				Y
15	7.9				Y
16	7.9				Y
17	7.8				Y
18	7.9				Y
19	8.0				Y
20	8.1				Y
21	8.1				Y
22	8.1				Y
23	8.1				Y
24	7.7				Y
25	8.1				Y
26	8.1				Y
27	8.1				Y
28	8.1				Y
29	8.2				Y
30	8.2				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

**PWS ID: 41** 0 0 2 3 6

**System Name:** Cottage Grove, City of

**Entry Point:** EP-B

**Sample Period:** November / 2022  
Month / Year

**Number of excursions\* during this month:** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.0

Alk   (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

**Print Name:** Ryan Kimball

**Signature:**   
**Date:** Decemebr , 01, 2022

Send to DWS within 10 days after end of sampling period