



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	7.9				Y
4	7.9				Y
5	7.9				Y
6	7.9				Y
7	7.8				Y
8	7.9				Y
9	8.0				Y
10	8.0				Y
11	8.0				Y
12	8.0				Y
13	8.0				Y
14	7.9				Y
15	7.9				Y
16	8.0				Y
17	8.0				Y
18	8.0				Y
19	8.0				Y
20	8.0				Y
21	8.0				Y
22	8.0				Y
23	8.0				Y
24	8.1				Y
25	8.1				Y
26	8.0				Y
27	8.0				Y
28	8.0				Y
29	8.0				Y
30	7.9				Y
31	8.0				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: July / 2023
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Ryan Kimball

Signature:

Date: August 01, 2023

Send to DWS within 10 days after end of sampling period