Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	8.0				Y
4	8.0				Y
5	8.0				Y
6	8.0				Y
7	8.0				Y
8	8.0				Y
9	8.0				Y
10	8.0				Y
11	8.0				Y
12	7.9				Y
13	7.9				Y
14	7.9				Y
15	7.9				Y
16	7.8				Y
17	7.8				Y
18	7.8				Y
19	7.8				Y
20	7.8				Y
21	7.9				Y
22	7.9				Y
23	7.9				Y
24	7.9				Y
25	7.8				Y
26	7.8				Y
27	7.8				Y
28	7.8				Y
29	7.8				Y
30	7.8				Y

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 3 6

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: September / 2023
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimun required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		( )

Print Name: Ryan Kimball

Signature:

Date: October 01, 2023

Send to DWS within 10 days after end of sampling period

OHA - Drinking Water Services, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/