



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.8				Y
2	7.7				Y
3	7.7				Y
4	7.7				Y
5	7.7				Y
6	7.6				Y
7	7.7				Y
8	7.7				Y
9	7.8				Y
10	7.8				Y
11	7.8				Y
12	7.8				Y
13	7.8				Y
14	7.9				Y
15	7.9				Y
16	7.9				Y
17	7.9				Y
18	7.9				Y
19	7.9				Y
20	7.9				Y
21	7.9				Y
22	7.9				Y
23	7.9				Y
24	7.9				Y
25	7.8				Y
26	7.8				Y
27	7.8				Y
28	7.8				Y
29	7.8				Y

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

0	0	2	3	6
---	---	---	---	---

System Name: Cottage Grove, City of

Entry Point: EP-B

Sample Period: February / 2024
Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Other		()

Print Name: Ryan Kimball

Signature:

Date: March, 4th, 2024

Send to DWS within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
