

DHS Oregon Department of Human Services						Water Quality Parameter Monitoring Form <b>Lead &amp; Copper Rule Corrosion Control</b>	
						<<Have	County: Lane Agency: REGION 2
<b>Day</b>	<b>pH</b>	<b>Alk</b>	<b>Phos</b>	<b>Sili</b>	<b>Y/N</b>	minimums	<b>ENTRY POINT</b>
1	7.4	N/A	N/A	N/A	YES	been met for	Entry Point: EP-B
2	7.4	N/A	N/A	N/A	YES	this day?	PWS ID 4100246B
3	7.4	N/A	N/A	N/A	YES		Creswell, City of
4	7.4	N/A	N/A	N/A	YES		System Name: Febuary 2021
5	7.4	N/A	N/A	N/A	YES		Sample period: Month/year
6	7.4	N/A	N/A	N/A	YES		<b>Number of excursions during this month: 0</b>
7	7.4	N/A	N/A	N/A	YES		(Over 9 excursions in 6 months is a violation.)
8	7.4	N/A	N/A	N/A	YES		Entry Point and Distribution excursions are
9	7.4	N/A	N/A	N/A	YES		cumulative). An 'excursion' is any day in which the
10	7.4	N/A	N/A	N/A	YES		water quality parameter(s) fall below the minimum
11	7.4	N/A	N/A	N/A	YES		set by the State.
12	7.4	N/A	N/A	N/A	YES		Reference: Minimum pH set on 11/3/2003 By John Potts.
13	7.4	N/A	N/A	N/A	YES		<b>Minimum Water Quality</b>
14	7.4	N/A	N/A	N/A	YES		<b>Parameter(s) as set by State:</b>
15	7.5	N/A	N/A	N/A	YES		pH 7.1
16	7.4	N/A	N/A	N/A	YES		Alk N/A (Alkalinity)
17	7.5	N/A	N/A	N/A	YES		PO4 N/A (Orthophosphate)
18	7.8	N/A	N/A	N/A	YES		Sili N/A (Silicate)
19	7.4	N/A	N/A	N/A	YES		<b>Print Name: Mike Howard</b>
20	7.4	N/A	N/A	N/A	YES		<b>Signature: Mike Howard</b>
21	7.4	N/A	N/A	N/A	YES		541-736-6015
22	7.5	N/A	N/A	N/A	YES		3/4/2021
23	7.5	N/A	N/A	N/A	YES		
24	7.5	N/A	N/A	N/A	YES		
25	7.5	N/A	N/A	N/A	YES		
26	7.4	N/A	N/A	N/A	YES		
27	7.4	N/A	N/A	N/A	YES		
28	7.4	N/A	N/A	N/A	YES		
29	x	N/A	N/A	N/A	x		
30	x	N/A	N/A	N/A	x		
31	x	N/A	N/A	N/A	x		
(No=N=Excursion)					<b>Total N's</b>	<b>0</b>	Send to DWP within 10 days after end of sampling period
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone:(971) 673-0405 Website: http://oregon.gov/DHS/ph/dwp/index.shtml							