	DHS								
•	Oregon Department of Human Services Lead & Co					Water Quality Parameter Monitoring Form			
						Copper Rule Corrosion Control			
Day	pH	Alk	Phos	Sili	Y/N	< <have< th=""><th>County: Lane</th><th>Agency: REGION 2</th><th></th></have<>	County: Lane	Agency: REGION 2	
1	7.9	N/A	N/A	N/A	YES	minimums		ENTRY POINT	
2	7.9	N/A	N/A	N/A	YES	been met for		Entry Point: EP-B	
3	7.9	N/A	N/A	N/A	YES	this day?		PWS ID 4100246B	
4	7.8	N/A	N/A	N/A	YES	,	System Name:	Creswell, City of	
5	7.8	N/A	N/A	N/A	YES		Sample period:	April-21	
6	8.0	N/A	N/A	N/A	YES		, ,	Month/year	
7	8.0	N/A	N/A	N/A	YES			•	
8	7.7	N/A	N/A	N/A	YES		Number of excursion	ons during this month:0	
9	7.7	N/A	N/A	N/A	YES			in 6 months is a violation.	
10	7.7	N/A	N/A	N/A	YES			ribution excursions are	
11	7.7	N/A	N/A	N/A	YES			ursion' is any day in which the	
12	7.7	N/A	N/A	N/A	YES			eter(s) fall below the minimun	
13	7.7	N/A	N/A	N/A	YES		set by the State.		
14	7.7	N/A	N/A	N/A	YES				
15	7.7	N/A	N/A	N/A	YES				
16 17	7.7	N/A N/A	N/A	N/A	YES YES	_	Defense Allelesse	-111 44/0/0000 Pu Islan Batta	
17	7.7	N/A N/A	N/A	N/A	YES		Reference: Minimun	pH set on 11/3/2003 By John Potts.	
19	7.7	N/A N/A	N/A N/A	N/A N/A	YES		Minimum Water Qu	olity	
20	7.9	N/A	N/A N/A	N/A N/A	YES	_	Parameter(s) as set		
21	7.9	N/A	N/A	N/A	YES		raiailletei(s) as se	t by State.	
22	7.8	N/A	N/A	N/A	YES		pH 7.1		
23	7.8	N/A	N/A	N/A	YES		Alk N/A	(Alkalinity)	
24	7.8	N/A	N/A	N/A	YES		PO4 N/A	(Orthophosphate)	
25	7.7	N/A	N/A	N/A	YES		Sili N/A	(Silicate)	
26	7.9	N/A	N/A	N/A	YES				
27	7.8	N/A	N/A	N/A	YES		Print Name:	Mike Howard	
28	7.8	N/A	N/A	N/A	YES				
29	7.8	N/A	N/A	N/A	YES		Signature: Mik	re Howard	
30	7.8	N/A	N/A	N/A	YES			541-736-6015	
31	Х	N/A	N/A	N/A	Х		5/1	1/2021	
o=N=Excursion)			Total N's			Send to DWP within 10 days after end of sampling period			