

DHS Oregon Department of Human Services						Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control		
Day	pH	Alk	Phos	Sili	Y/N	<<Have		
1	7.5	N/A	N/A	N/A	YES	minimums	County: Lane Agency: REGION 2	
2	7.5	N/A	N/A	N/A	YES	been met for	ENTRY POINT	
3	7.7	N/A	N/A	N/A	YES	this day?	Entry Point: EP-B	
4	7.7	N/A	N/A	N/A	YES		PWS ID 4100246B	
5	7.7	N/A	N/A	N/A	YES		System Name: <u>Creswell, City of</u>	
6	7.7	N/A	N/A	N/A	YES		Sample period: <u>June-21</u>	
7	7.7	N/A	N/A	N/A	YES		Month/year	
8	7.8	N/A	N/A	N/A	YES		Number of excursions during this month: <u>0</u>	
9	7.7	N/A	N/A	N/A	YES		<i>(Over 9 excursions in 6 months is a violation.</i>	
10	7.6	N/A	N/A	N/A	YES		<i>Entry Point and Distribution excursions are</i>	
11	7.5	N/A	N/A	N/A	YES		<i>cumulative). An 'excursion' is any day in which the</i>	
12	7.6	N/A	N/A	N/A	YES		<i>water quality parameter(s) fall below the minimum</i>	
13	7.6	N/A	N/A	N/A	YES		<i>set by the State.</i>	
14	7.6	N/A	N/A	N/A	YES			
15	7.6	N/A	N/A	N/A	YES		Reference: Minimum pH set on 11/3/2003 By John Potts.	
16	7.6	N/A	N/A	N/A	YES			
17	7.6	N/A	N/A	N/A	YES			
18	7.6	N/A	N/A	N/A	YES			
19	7.7	N/A	N/A	N/A	YES			
20	7.7	N/A	N/A	N/A	YES			
21	7.5	N/A	N/A	N/A	YES			
22	7.6	N/A	N/A	N/A	YES			
23	7.6	N/A	N/A	N/A	YES			
24	7.6	N/A	N/A	N/A	YES			
25	7.6	N/A	N/A	N/A	YES			
26	7.6	N/A	N/A	N/A	YES			
27	7.5	N/A	N/A	N/A	YES			
28	7.4	N/A	N/A	N/A	YES			
29	7.4	N/A	N/A	N/A	YES			
30	7.4	N/A	N/A	N/A	YES			
31	x	N/A	N/A	N/A	x			
(No=N=Excursion) Total N's							7/1/2021	
						Send to DWP within 10 days after end of sampling period		
						DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone:(971) 673-0405 Website: http://oregon.gov/DHS/ph/dwp/index.shtml		

County: Lane Agency: REGION 2
ENTRY POINT
 Entry Point: EP-B
 PWS ID 4100246B
 System Name: Creswell, City of
 Sample period: June-21
 Month/year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference: Minimum pH set on 11/3/2003 By John Potts.

Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.1
Alk	N/A (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: Mike Howard

Signature: Mike Howard

541-736-6015

7/1/2021