

)('

DHS
Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane	Agency: REGION 2
1	7.6	N/A	N/A	N/A	YES			ENTRY POINT Entry Point: EP-B PWS ID 4100246B Creswell, City of
2	7.6	N/A	N/A	N/A	YES			
3	7.6	N/A	N/A	N/A	YES			System Name:
4	7.6	N/A	N/A	N/A	YES			Sample period: August-21
5	7.6	N/A	N/A	N/A	YES			Month/year
6	7.7	N/A	N/A	N/A	YES			Number of excursions during this month: <u> 0 </u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i> Reference: Minimum pH set on 11/3/2003 By John Potts. Minimum Water Quality Parameter(s) as set by State: pH <u> 7.1 </u> Alk N/A (Alkalinity) PO4 N/A (Orthophosphate) Sili N/A (Silicate)
7	7.7	N/A	N/A	N/A	YES			
8	7.6	N/A	N/A	N/A	YES			
9	7.6	N/A	N/A	N/A	YES			
10	7.6	N/A	N/A	N/A	YES			
11	7.6	N/A	N/A	N/A	YES			
12	7.5	N/A	N/A	N/A	YES			
13	7.5	N/A	N/A	N/A	YES			
14	7.6	N/A	N/A	N/A	YES			
15	7.6	N/A	N/A	N/A	YES			
16	7.6	N/A	N/A	N/A	YES			
17	7.5	N/A	N/A	N/A	YES			
18	7.6	N/A	N/A	N/A	YES			
19	7.6	N/A	N/A	N/A	YES			
20	7.6	N/A	N/A	N/A	YES			
21	7.6	N/A	N/A	N/A	YES			
22	7.6	N/A	N/A	N/A	YES			
23	7.8	N/A	N/A	N/A	YES			
24	7.9	N/A	N/A	N/A	YES			
25	7.8	N/A	N/A	N/A	YES			
26	7.8	N/A	N/A	N/A	YES			
27	7.8	N/A	N/A	N/A	YES			
28	7.8	N/A	N/A	N/A	YES			
29	7.8	N/A	N/A	N/A	YES			
30	7.8	N/A	N/A	N/A	YES			
31	7.8	N/A	N/A	N/A	YES			

(No=N=Excursion)

Total N's

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone:(971) 673-0405

Website: <http://oregon.gov/DHS/ph/dwp/index.shtml>

Print Name: Mike Howard

Signature: Mike Howard

541-736-6015

9/2/2021