

DHS Oregon Department of Human Services						Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control	
Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B Creswell, City of September-21 Month/year
1	7.8	N/A	N/A	N/A	YES		Number of excursions during this month: <u> 0 </u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i>
2	7.6	N/A	N/A	N/A	YES		
3	7.6	N/A	N/A	N/A	YES		
4	7.6	N/A	N/A	N/A	YES		
5	7.5	N/A	N/A	N/A	YES		
6	7.5	N/A	N/A	N/A	YES		
7	8.1	N/A	N/A	N/A	YES		
8	8.1	N/A	N/A	N/A	YES		
9	7.9	N/A	N/A	N/A	YES		
10	7.9	N/A	N/A	N/A	YES		
11	7.9	N/A	N/A	N/A	YES		
12	7.9	N/A	N/A	N/A	YES		
13	7.9	N/A	N/A	N/A	YES		
14	7.6	N/A	N/A	N/A	YES		
15	7.6	N/A	N/A	N/A	YES		
16	7.6	N/A	N/A	N/A	YES		
17	7.6	N/A	N/A	N/A	YES		
18	7.6	N/A	N/A	N/A	YES		
19	7.6	N/A	N/A	N/A	YES		
20	7.6	N/A	N/A	N/A	YES		
21	7.5	N/A	N/A	N/A	YES		
22	7.5	N/A	N/A	N/A	YES		
23	7.6	N/A	N/A	N/A	YES		
24	7.6	N/A	N/A	N/A	YES		
25	7.6	N/A	N/A	N/A	YES		
26	7.6	N/A	N/A	N/A	YES		
27	7.6	N/A	N/A	N/A	YES		
28	7.6	N/A	N/A	N/A	YES		
29	7.6	N/A	N/A	N/A	YES		
30	7.6	N/A	N/A	N/A	YES		
31	x	N/A	N/A	N/A	x		
(No=N=Excursion) Total N's						Send to DWP within 10 days after end of sampling period	Reference: Minimum pH set on 11/3/2003 By John Potts. Minimum Water Quality Parameter(s) as set by State: pH <u> 7.1 </u> Alk N/A (Alkalinity) PO4 N/A (Orthophosphate) Sili N/A (Silicate)
						Print Name: Mike Howard Signature: Mike Howard <div style="text-align: right;"> 541-736-6015 10/1/2021 </div>	
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone:(971) 673-0405 Website: http://oregon.gov/DHS/ph/dwp/index.shtml							