	DHS Oregon Departmen of Human Services				Lead & C	,	ameter Monitoring Form Prosion Control	
D			DI	0				
Day	рН	Alk	Phos	Sili	Y/N	< <have< td=""><td>County: Lane</td><td>Agency: REGION 2</td></have<>	County: Lane	Agency: REGION 2
1	7.9	N/A	N/A	N/A	YES	minimums		ENTRY POINT
2	7.9	N/A	N/A	N/A	YES	been met for		Entry Point: EP-B
3	7.9	N/A	N/A	N/A	YES	this day?		PWS ID 4100246B
4	7.5	N/A	N/A	N/A	YES		System Name:	Creswell, City of
5	7.6	N/A	N/A	N/A	YES		Sample period:	October-21
6	7.6	N/A	N/A	N/A	YES			Month/year
7	7.6	N/A	N/A	N/A	YES			na durina this manth. O
8	7.6	N/A	N/A	N/A	YES	_	Number of excursions during this month:	
<u>9</u> 10	7.6	N/A N/A	N/A N/A	N/A N/A	YES	_	(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are	
10	7.6	N/A N/A	N/A N/A	N/A N/A	YES		cumulative). An 'excursion' is any day in which the	
12	7.6	N/A	N/A	N/A	YES		water quality parameter(s) fall below the minimun	
13	7.6	N/A	N/A	N/A	YES		set by the State.	
14	7.6	N/A	N/A	N/A	YES		, , , , , , , , , , , , , , , , , , , ,	
15	7.6	N/A	N/A	N/A	YES			
16	7.6	N/A	N/A	N/A	YES			
17	7.5	N/A	N/A	N/A	YES		Reference: Minimun pH set on 11/3/2003 By John Potts.	
18	7.5	N/A	N/A	N/A	YES			
19	7.6	N/A	N/A	N/A	YES		Minimum Water Quality Parameter(s) as set by State:	
20 21	7.6	N/A N/A	N/A N/A	N/A N/A	YES		Parameter(s) as set	by State:
21	7.6	N/A N/A	N/A N/A	N/A N/A	YES		pH 7.1	
23	7.6	N/A	N/A N/A	N/A N/A	YES		Alk N/A	(Alkalinity)
24	7.6	N/A	N/A	N/A	YES		PO4 N/A	(Orthophosphate)
25	7.6	N/A	N/A	N/A	YES		Sili N/A	(Silicate)
26	7.6	N/A	N/A	N/A	YES			
27	7.6	N/A	N/A	N/A	YES		Print Name:	Mike Howard
28	7.5	N/A	N/A	N/A	YES			
29	7.5	N/A	N/A	N/A	YES		Signature: Mike	e Howard
30	7.5	N/A	N/A	N/A	YES			541-736-6015
31	7.5	N/A	N/A	N/A	YES		11/1/2021	
=N=Excursion)			Total N's			Send to DWP wi	thin 10 days after end of san	npling period
					DHS, Drinking Phone:(971) 6		Box 14350, Portland, OR 97: Website: http://orego	293-0350 n.gov/DHS/ph/dwp/index.shtml