

)('

**DHS**  
Oregon Department  
of Human Services

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	N/A	N/A	N/A	YES
2	7.8	N/A	N/A	N/A	YES
3	7.8	N/A	N/A	N/A	YES
4	7.7	N/A	N/A	N/A	YES
5	7.6	N/A	N/A	N/A	YES
6	7.6	N/A	N/A	N/A	YES
7	7.6	N/A	N/A	N/A	YES
8	7.7	N/A	N/A	N/A	YES
9	7.6	N/A	N/A	N/A	YES
10	7.6	N/A	N/A	N/A	YES
11	7.6	N/A	N/A	N/A	YES
12	7.6	N/A	N/A	N/A	YES
13	7.6	N/A	N/A	N/A	YES
14	7.6	N/A	N/A	N/A	YES
15	7.7	N/A	N/A	N/A	YES
16	7.7	N/A	N/A	N/A	YES
17	7.7	N/A	N/A	N/A	YES
18	7.7	N/A	N/A	N/A	YES
19	7.7	N/A	N/A	N/A	YES
20	7.6	N/A	N/A	N/A	YES
21	7.6	N/A	N/A	N/A	YES
22	7.6	N/A	N/A	N/A	YES
23	7.6	N/A	N/A	N/A	YES
24	7.7	N/A	N/A	N/A	YES
25	7.7	N/A	N/A	N/A	YES
26	7.6	N/A	N/A	N/A	YES
27	7.6	N/A	N/A	N/A	YES
28	7.6	N/A	N/A	N/A	YES
29	7.7	N/A	N/A	N/A	YES
30	7.6	N/A	N/A	N/A	YES
31	7.7	N/A	N/A	N/A	YES

<<Have  
minimums  
been met for  
this day?

County: Lane Agency: REGION 2  
**ENTRY POINT**  
**Entry Point: EP-B**  
**PWS ID 4100246B**  
System Name: Creswell, City of  
Sample period: March-22  
Month/year

Number of excursions during this month: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference: Minimum pH set on 11/3/2003 By John Potts.

Minimum Water Quality Parameter(s) as set by State:	
pH	7.1
Alk	N/A (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

**Print Name: Mike Howard**

**Signature: Mike Howard**  
**541-736-6015**  
**4/1/2022**

(No=N=Excursion) **Total N's**

Send to DWP within 10 days after end of sampling period