



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>May-22</u> Month/year
1	7.8	N/A	N/A	N/A	YES		
2	7.8	N/A	N/A	N/A	YES		
3	7.8	N/A	N/A	N/A	YES		
4	7.8	N/A	N/A	N/A	YES		
5	7.8	N/A	N/A	N/A	YES		
6	7.8	N/A	N/A	N/A	YES		
7	7.7	N/A	N/A	N/A	YES		
8	7.7	N/A	N/A	N/A	YES		
9	7.7	N/A	N/A	N/A	YES		
10	7.7	N/A	N/A	N/A	YES		
11	7.6	N/A	N/A	N/A	YES		
12	7.7	N/A	N/A	N/A	YES		
13	7.7	N/A	N/A	N/A	YES		
14	7.7	N/A	N/A	N/A	YES		
15	7.7	N/A	N/A	N/A	YES		
16	7.7	N/A	N/A	N/A	YES		
17	7.7	N/A	N/A	N/A	YES		
18	7.8	N/A	N/A	N/A	YES		
19	7.8	N/A	N/A	N/A	YES		
20	7.8	N/A	N/A	N/A	YES		
21	7.8	N/A	N/A	N/A	YES		
22	7.8	N/A	N/A	N/A	YES		
23	7.7	N/A	N/A	N/A	YES		
24	7.8	N/A	N/A	N/A	YES		
25	7.8	N/A	N/A	N/A	YES		
26	7.8	N/A	N/A	N/A	YES		
27	7.8	N/A	N/A	N/A	YES		
28	7.8	N/A	N/A	N/A	YES		
29	7.8	N/A	N/A	N/A	YES		
30	7.8	N/A	N/A	N/A	YES		
31	7.8	N/A	N/A	N/A	YES		
(No=N=Excursion) Total N's							Number of excursions during this month: <u>0</u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i> Reference: Minimum pH set on 11/3/2003 By John Potts. <div style="border: 1px solid black; padding: 5px;"> Minimum Water Quality Parameter(s) as set by State: pH <u>7.1</u> Alk N/A (Alkalinity) PO4 N/A (Orthophosphate) Sili N/A (Silicate) </div> Print Name: <u>Mike Howard</u> Signature: <u>Mike Howard</u> 541-736-6015 6/2/2022
							Send to DWP within 10 days after end of sampling period