

)('

DHS
Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	N/A	N/A	N/A	YES
2	7.7	N/A	N/A	N/A	YES
3	7.7	N/A	N/A	N/A	YES
4	7.8	N/A	N/A	N/A	YES
5	7.9	N/A	N/A	N/A	YES
6	7.9	N/A	N/A	N/A	YES
7	7.8	N/A	N/A	N/A	YES
8	7.8	N/A	N/A	N/A	YES
9	7.8	N/A	N/A	N/A	YES
10	7.7	N/A	N/A	N/A	YES
11	7.8	N/A	N/A	N/A	YES
12	7.8	N/A	N/A	N/A	YES
13	7.8	N/A	N/A	N/A	YES
14	7.8	N/A	N/A	N/A	YES
15	7.8	N/A	N/A	N/A	YES
16	7.8	N/A	N/A	N/A	YES
17	7.8	N/A	N/A	N/A	YES
18	7.8	N/A	N/A	N/A	YES
19	7.9	N/A	N/A	N/A	YES
20	7.8	N/A	N/A	N/A	YES
21	7.9	N/A	N/A	N/A	YES
22	7.9	N/A	N/A	N/A	YES
23	7.9	N/A	N/A	N/A	YES
24	7.8	N/A	N/A	N/A	YES
25	7.7	N/A	N/A	N/A	YES
26	7.8	N/A	N/A	N/A	YES
27	7.8	N/A	N/A	N/A	YES
28	7.8	N/A	N/A	N/A	YES
29	7.8	N/A	N/A	N/A	YES
30	7.8	N/A	N/A	N/A	YES
31	7.8	N/A	N/A	N/A	YES
Total N's					

<<Have minimums been met for this day?

County: Lane Agency: REGION 2
ENTRY POINT
Entry Point: EP-B
PWS ID 4100246B

System Name: Creswell, City of
Sample period: July-22
Month/year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference: Minimum pH set on 11/3/2003 By John Potts.

Minimum Water Quality Parameter(s) as set by State:	
pH	7.1
Alk	N/A (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: **Mike Howard**

Signature: **Mike Howard**

8/1/2022 **541-736-6015**