

)'(

**DHS**  
Oregon Department  
of Human Services

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane	Agency: REGION 2
1	7.8	N/A	N/A	N/A	YES			<b>ENTRY POINT</b>
2	7.8	N/A	N/A	N/A	YES			<b>Entry Point: EP-B</b>
3	7.8	N/A	N/A	N/A	YES			<b>PWS ID 4100246B</b>
4	7.8	N/A	N/A	N/A	YES			<b>Creswell, City of</b>
5	7.7	N/A	N/A	N/A	YES			<b>September-22</b>
6	7.7	N/A	N/A	N/A	YES			Month/year
7	7.7	N/A	N/A	N/A	YES			
8	7.6	N/A	N/A	N/A	YES			
9	7.6	N/A	N/A	N/A	YES			
10	7.6	N/A	N/A	N/A	YES			
11	7.6	N/A	N/A	N/A	YES			
12	7.6	N/A	N/A	N/A	YES			
13	7.6	N/A	N/A	N/A	YES			
14	7.7	N/A	N/A	N/A	YES			
15	7.6	N/A	N/A	N/A	YES			
16	7.6	N/A	N/A	N/A	YES			
17	7.6	N/A	N/A	N/A	YES			
18	7.6	N/A	N/A	N/A	YES			
19	7.6	N/A	N/A	N/A	YES			
20	7.6	N/A	N/A	N/A	YES			
21	7.5	N/A	N/A	N/A	YES			
22	7.7	N/A	N/A	N/A	YES			
23	7.7	N/A	N/A	N/A	YES			
24	7.7	N/A	N/A	N/A	YES			
25	7.7	N/A	N/A	N/A	YES			
26	7.7	N/A	N/A	N/A	YES			
27	7.7	N/A	N/A	N/A	YES			
28	7.7	N/A	N/A	N/A	YES			
29	7.7	N/A	N/A	N/A	YES			
30	7.7	N/A	N/A	N/A	YES			
31	x	N/A	N/A	N/A	x			

System Name: \_\_\_\_\_  
Sample period: \_\_\_\_\_

**Number of excursions during this month:   0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference: Minimum pH set on 11/3/2003 By John Potts.

<b>Minimum Water Quality</b>	
Parameter(s) as set by State:	
pH	7.1
Alk	N/A (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

**Print Name: Mike Howard**

**Signature: Mike Howard**

**541-736-6015**

**10/1/2022**