



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 <b>ENTRY POINT</b> Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>October-22</u> Month/year
1	7.7	N/A	N/A	N/A	YES		Number of excursions during this month: <u>0</u> <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i>  Reference: Minimum pH set on 11/3/2003 By John Potts.  <div style="border: 1px solid black; padding: 5px;"> <b>Minimum Water Quality Parameter(s) as set by State:</b>  <p>pH <u>7.1</u></p> <p>Alk N/A (Alkalinity)</p> <p>PO4 N/A (Orthophosphate)</p> <p>Sili N/A (Silicate)</p> </div> Print Name: <b>Mike Howard</b>  Signature: <b>Mike Howard</b>  <div style="text-align: right;">541-736-6015</div> 11/3/2022
2	7.7	N/A	N/A	N/A	YES		
3	7.6	N/A	N/A	N/A	YES		
4	7.7	N/A	N/A	N/A	YES		
5	7.7	N/A	N/A	N/A	YES		
6	7.7	N/A	N/A	N/A	YES		
7	7.7	N/A	N/A	N/A	YES		
8	7.7	N/A	N/A	N/A	YES		
9	7.7	N/A	N/A	N/A	YES		
10	7.7	N/A	N/A	N/A	YES		
11	7.7	N/A	N/A	N/A	YES		
12	7.7	N/A	N/A	N/A	YES		
13	7.7	N/A	N/A	N/A	YES		
14	7.7	N/A	N/A	N/A	YES		
15	7.6	N/A	N/A	N/A	YES		
16	7.6	N/A	N/A	N/A	YES		
17	7.7	N/A	N/A	N/A	YES		
18	7.7	N/A	N/A	N/A	YES		
19	7.7	N/A	N/A	N/A	YES		
20	7.6	N/A	N/A	N/A	YES		
21	7.6	N/A	N/A	N/A	YES		
22	7.6	N/A	N/A	N/A	YES		
23	7.6	N/A	N/A	N/A	YES		
24	7.6	N/A	N/A	N/A	YES		
25	7.6	N/A	N/A	N/A	YES		
26	7.6	N/A	N/A	N/A	YES		
27	7.6	N/A	N/A	N/A	YES		
28	7.6	N/A	N/A	N/A	YES		
29	7.6	N/A	N/A	N/A	YES		
30	7.6	N/A	N/A	N/A	YES		
31	7.6	N/A	N/A	N/A	YES		
(No=N=Excursion) <b>Total N's</b>						Send to DWP within 10 days after end of sampling period	