	DHS								
•	Oregon Department					Water Quality Parameter Monitoring Form			
	of Human Services				Lead & C	Copper Rule Co	orrosion Control		
	•								
Day	рН	Alk	Phos	Sili	Y/N	< <have< td=""><td>County: Lane</td><td>Agency: REGION 2</td></have<>	County: Lane	Agency: REGION 2	
1	7.6	N/A	N/A	N/A	YES	minimums		ENTRY POINT	
2	7.6	N/A	N/A	N/A	YES	been met for		Entry Point: EP-B	
3	7.7	N/A	N/A	N/A	YES	this day?		PWS ID 4100246B	
4	7.7	N/A	N/A	N/A	YES		System Name:	Creswell, City of	
5	7.7	N/A	N/A	N/A	YES		Sample period:	November-22	
6	7.7	N/A	N/A	N/A	YES			Month/year	
7	7.7	N/A	N/A	N/A	YES				
8	7.9	N/A	N/A	N/A	YES		Number of excurs	ions during this month: <u>0</u>	
9	7.7	N/A	N/A	N/A	YES		(Over 9 excursions	in 6 months is a violation.	
10	7.8	N/A	N/A	N/A	YES		Entry Point and Dis	tribution excursions are	
11	7.8	N/A	N/A	N/A	YES		cumulative). An 'ex	cursion' is any day in which the	
12	7.8	N/A	N/A	N/A	YES		water quality param	neter(s) fall below the minimun	
13	7.8	N/A	N/A	N/A	YES		set by the State.		
14	7.8	N/A	N/A	N/A	YES				
15	7.8	N/A	N/A	N/A	YES				
16	7.8	N/A	N/A	N/A	YES				
17	7.8	N/A	N/A	N/A	YES		Reference: Minimu	n pH set on 11/3/2003 By John Potts.	
18	7.8	N/A	N/A	N/A	YES				
19	7.7	N/A	N/A	N/A	YES		Minimum Water Q	uality	
20	7.7	N/A	N/A	N/A	YES		Parameter(s) as s	et by State:	
21	7.9	N/A	N/A	N/A	YES				
22	7.9	N/A	N/A	N/A	YES		pH 7.1		
23	7.7	N/A	N/A	N/A	YES		Alk N/A	(Alkalinity)	
24	7.7	N/A	N/A	N/A	YES		PO4 N/A	(Orthophosphate)	
25	7.7	N/A	N/A	N/A	YES		Sili N/A	(Silicate)	
26	7.7	N/A	N/A	N/A	YES				
27	7.7	N/A	N/A	N/A	YES		Print Name:	Mike Howard	
28	7.7	N/A	N/A	N/A	YES				
29	7.5	N/A	N/A	N/A	YES		Signature: Mi	ke Howard	
30	7.7	N/A	N/A	N/A	YES			541-736-6015	
31	x	x	х	х	x		1:	2/1/2022	
lo=N=Excursion)		Total N's				Send to DWP wit	Send to DWP within 10 days after end of sampling period		
							Box 14350, Portland, OF		
					Phone:(971)	673-0405	Website: http://oreg	jon.gov/DHS/ph/dwp/index.shtml	