



DHS

Oregon Department of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 <b>ENTRY POINT</b> Entry Point: EP-B <b>PWS ID 4100246B</b> System Name: <u>Creswell, City of</u> Sample period: <u>January-23</u> Month/year
1	7.4	42	N/A	N/A	YES		
2	7.4	40	N/A	N/A	YES		
3	7.3	39	N/A	N/A	YES		
4	7.2	44	N/A	N/A	YES		
5	7.3	44	N/A	N/A	YES		
6	7.4	46	N/A	N/A	YES		
7	7.4	46	N/A	N/A	YES		
8	7.4	44	N/A	N/A	YES		
9	7.4	44	N/A	N/A	YES		
10	7.4	48	N/A	N/A	YES		
11	7.4	46	N/A	N/A	YES		
12	7.4	44	N/A	N/A	YES		
13	7.4	44	N/A	N/A	YES		
14	7.4	44	N/A	N/A	YES		
15	7.4	44	N/A	N/A	YES		
16	7.4	44	N/A	N/A	YES		
17	7.3	43	N/A	N/A	YES		
18	7.3	42	N/A	N/A	YES		
19	7.3	40	N/A	N/A	YES		
20	7.3	40	N/A	N/A	YES		
21	7.3	42	N/A	N/A	YES		
22	7.3	42	N/A	N/A	YES		
23	7.3	42	N/A	N/A	YES		
24	7.3	40	N/A	N/A	YES		
25	7.3	45	N/A	N/A	YES		
26	7.4	46	N/A	N/A	YES		
27	7.4	46	N/A	N/A	YES		
28	7.4	44	N/A	N/A	YES		
29	7.4	44	N/A	N/A	YES		
30	7.4	44	N/A	N/A	YES		
31	7.4	40	N/A	N/A	YES		
(No=N=Excursion)						<b>Total N's</b>	Send to DWP within 10 days after end of sampling period

Number of excursions during this month: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference: Minimum pH set on 11/3/2003 By John Potts.  
 Minimum Alkalinity set on 2/1/2023 by Amy Bleekman

Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.1
Alk	33 (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

**Print Name: Mike Howard**

**Signature: Mike Howard**

**541-736-6015**

**2/2/2023**