

)('

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>April-23</u> Month/year
1	7.6	40	N/A	N/A	YES		
2	7.6	40	N/A	N/A	YES		
3	7.6	40	N/A	N/A	YES		
4	7.5	38	N/A	N/A	YES		
5	7.7	40	N/A	N/A	YES		
6	7.7	40	N/A	N/A	YES		
7	7.7	42	N/A	N/A	YES		
8	7.7	42	N/A	N/A	YES		
9	7.7	42	N/A	N/A	YES		
10	7.7	42	N/A	N/A	YES		
11	7.6	40	N/A	N/A	YES		
12	7.7	37	N/A	N/A	YES		
13	7.6	40	N/A	N/A	YES		
14	7.6	40	N/A	N/A	YES		
15	7.6	40	N/A	N/A	YES		
16	7.6	40	N/A	N/A	YES		
17	7.6	38	N/A	N/A	YES		
18	7.8	40	N/A	N/A	YES		
19	7.6	38	N/A	N/A	YES		
20	7.4	38	N/A	N/A	YES		
21	7.4	40	N/A	N/A	YES		
22	7.4	40	N/A	N/A	YES		
23	7.5	40	N/A	N/A	YES		
24	7.5	40	N/A	N/A	YES		
25	7.5	38	N/A	N/A	YES		
26	7.4	42	N/A	N/A	YES		
27	7.5	42	N/A	N/A	YES		
28	7.5	44	N/A	N/A	YES		
29	7.5	44	N/A	N/A	YES		
30	7.5	42	N/A	N/A	YES		
31	x	x	x	x	x		

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference: Minimum pH set on 11/3/2003 By John Potts.
Minimum Alkalinity set on 2/1/2023 by Amy Bleekman

Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.1
Alk	33 (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: Mike Howard

Signature: Mike Howard

4/4/2023 **541-736-6015**