

)('

DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane	Agency: REGION 2							
1	7.4	38	N/A	N/A	YES		ENTRY POINT Entry Point: EP-B PWS ID 4100246B Creswell, City of August-23 Month/year Number of excursions during this month: 0 <i>(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.</i> Reference: Minimum pH set on 11/3/2003 By John Potts. Minimum Alkalinity set on 2/1/2023 by Amy Bleekman Minimum Water Quality Parameter(s) as set by State: <table border="1"> <tr><td>pH</td><td>7.1</td></tr> <tr><td>Alk</td><td>33 (Alkalinity)</td></tr> <tr><td>PO4</td><td>N/A (Orthophosphate)</td></tr> <tr><td>Sili</td><td>N/A (Silicate)</td></tr> </table>	pH	7.1	Alk	33 (Alkalinity)	PO4	N/A (Orthophosphate)	Sili	N/A (Silicate)
pH	7.1														
Alk	33 (Alkalinity)														
PO4	N/A (Orthophosphate)														
Sili	N/A (Silicate)														
2	7.4	39	N/A	N/A	YES										
3	7.4	38	N/A	N/A	YES										
4	7.4	38	N/A	N/A	YES										
5	7.4	40	N/A	N/A	YES										
6	7.4	40	N/A	N/A	YES										
7	7.4	40	N/A	N/A	YES										
8	7.4	38	N/A	N/A	YES										
9	7.3	40	N/A	N/A	YES										
10	7.4	40	N/A	N/A	YES										
11	7.4	40	N/A	N/A	YES										
12	7.4	40	N/A	N/A	YES										
13	7.4	40	N/A	N/A	YES										
14	7.4	40	N/A	N/A	YES										
15	7.4	38	N/A	N/A	YES										
16	7.4	39	N/A	N/A	YES										
17	7.4	40	N/A	N/A	YES										
18	7.4	40	N/A	N/A	YES										
19	7.3	40	N/A	N/A	YES										
20	7.3	40	N/A	N/A	YES										
21	7.3	40	N/A	N/A	YES										
22	7.7	43	N/A	N/A	YES										
23	7.6	43	N/A	N/A	YES										
24	7.5	38	N/A	N/A	YES										
25	7.5	38	N/A	N/A	YES										
26	7.6	40	N/A	N/A	YES										
27	7.5	40	N/A	N/A	YES										
28	7.5	40	N/A	N/A	YES										
29	7.5	38	N/A	N/A	YES										
30	7.5	40	N/A	N/A	YES										
31	7.5	40	N/A	N/A	YES										
(No=N=Excursion)	Total N's						Send to DWP within 10 days after end of sampling period								

System Name:
Sample period:

Number of excursions during this month: 0
*(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 cumulative). An 'excursion' is any day in which the
 water quality parameter(s) fall below the minimum
 set by the State.*

Reference: Minimum pH set on 11/3/2003 By John Potts.
 Minimum Alkalinity set on 2/1/2023 by Amy Bleekman

Minimum Water Quality	
Parameter(s) as set by State:	
pH	7.1
Alk	33 (Alkalinity)
PO4	N/A (Orthophosphate)
Sili	N/A (Silicate)

Print Name: Mike Howard

Signature: Mike Howard

541-736-6015

9/1/2023