



DHS

Oregon Department
of Human Services

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N	<<Have minimums been met for this day?	County: Lane Agency: REGION 2 ENTRY POINT Entry Point: EP-B PWS ID 4100246B System Name: <u>Creswell, City of</u> Sample period: <u>October-23</u> Month/year
1	7.4	40	N/A	N/A	YES		
2	7.2	40	N/A	N/A	YES		
3	7.6	42	N/A	N/A	YES		
4	7.5	40	N/A	N/A	YES		
5	7.5	40	N/A	N/A	YES		
6	7.5	40	N/A	N/A	YES		
7	7.5	40	N/A	N/A	YES		
8	7.5	40	N/A	N/A	YES		
9	7.5	40	N/A	N/A	YES		
10	7.5	40	N/A	N/A	YES		
11	7.8	38	N/A	N/A	YES		
12	7.4	40	N/A	N/A	YES		
13	7.4	42	N/A	N/A	YES		
14	7.4	42	N/A	N/A	YES		
15	7.4	40	N/A	N/A	YES		
16	7.6	44	N/A	N/A	YES		
17	7.5	42	N/A	N/A	YES		
18	7.6	40	N/A	N/A	YES		
19	7.5	40	N/A	N/A	YES		
20	7.5	40	N/A	N/A	YES		
21	7.5	40	N/A	N/A	YES		
22	7.4	40	N/A	N/A	YES		
23	7.4	38	N/A	N/A	YES		
24	7.4	40	N/A	N/A	YES		
25	7.6	41	N/A	N/A	YES		
26	7.5	40	N/A	N/A	YES		
27	7.5	40	N/A	N/A	YES		
28	7.5	40	N/A	N/A	YES		
29	7.5	40	N/A	N/A	YES		
30	7.5	39	N/A	N/A	YES		
31	7.5	40	N/A	N/A	YES		
(No=N=Excursion)						Total N's	Send to DWP within 10 days after end of sampling period
Reference: Minimum pH set on 11/3/2003 By John Potts. Minimum Alkalinity set on 2/1/2023 by Amy Bleekman Minimum Water Quality Parameter(s) as set by State: pH <u>7.1</u> Alk <u>33</u> (Alkalinity) PO4 N/A (Orthophosphate) Sili N/A (Silicate)							
Print Name: Mike Howard Signature: Mike Howard 541-736-6015 11/2/2023							
DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone: (971) 673-0405 Website: http://oregon.gov/DHS/ph/dwp/index.shtml							